

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3725-0610:127 Page 1 of 1

CATEGORY: Door Hardware (Fire-Rated)

LISTEE: Dorma Door Controls, Drawer AC, Reamstown, PA 17567-0411
Contact: Rick Loose (717) 336-3881 FAX (717) 336-2106

DESIGN: Models F9300 Series rim type fire exit hardware. Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, NFPA 80, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number and UL label.

APPROVAL: Listed fire exit hardware for use with swinging type fire doors measuring up to 48" in width by 96" in high (single) and 96" in width by 96" in high (double) where permitted per code. Suitable for location rated up to 3-hour. When used in pairs, Model F1300 keyed removable mullion assembly may be used.

09-15-2000



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 21, 2004** *Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy**
Program Manager